


FIRE ALARM SYSTEM MONTHLY TEST RECORD

Every month the following tests shall be conducted and if a fault is established appropriate corrective action shall be taken. (Initial each area.)

| Month | (A) Manual Pull Stations | (B) Bells | (C) Annunciator | (D) Trouble Signal | (E) Battery Condition | Date (mm/dd/yy) | Signature |
|-----------|--------------------------------|--------------|--------------------|--------------------------|-----------------------------|--------------------|-----------|
| January | | | | | | | |
| February | | | | | | | |
| March | | | | | | | |
| April | | | | | | | |
| May | | | | | | | |
| June | | | | | | | |
| July | | | | | | | |
| August | | | | | | | |
| September | | | | | | | |
| October | | | | | | | |
| November | | | | | | | |
| December | | | | | | | |

- (A) One (1) alarm initiating pull station device shall be operated on a rotational basis and shall initiate an alarm condition.
- (B) Intended function of all alarm audible signal appliances (bells) shall be ensured.
- (C) The annunciator panel shall be checked to ensure that the tested devices annunciate correctly.
- (D) Intended function of audible and visual trouble signals shall be ensured.
- (E) Fire alarm batteries shall be visually inspected.



suite 210, building 151, 10090 - 152 street
surrey, british columbia v3r 8x8
telephone: (778) 863-7147
facsimile: (604)-552-7909
url: www.anubissystems.com
email: sales@anubissystems.com